

設置前



Project: 250 Bishopsgate

Client: Japan System Planning Co (UK)	Chemtest Job No.:	18-08413			
Quotation No.:	Chemtest Sample ID.:	598264			
	Client Sample ID.:	Fe			
	Sample Type:	WATER			
	Date Sampled:	23-Mar-2018			
Determinand	Accred.	SOP	Units	LOD	
Iron (Dissolved)	N	1450	µg/l	20	1100

Results - Water

設置 3 週間後



Project: RBS250 Bishops Gate

Client: Japan System Planning Co (UK)	Chemtest Job No.:	18-10804			
Quotation No.: Q16-06534	Chemtest Sample ID.:	610053			
	Client Sample ID.:	1			
	Sample Type:	WATER			
	Date Sampled:	16-Apr-2018			
Determinand	Accred.	SOP	Units	LOD	
Iron (Dissolved)	N	1450	µg/l	20	410

Results - Water

設置 4 週間後



Project: 250 Bishopsgate (LTHW System)

Client: Japan System Planning Co (UK)	Chemtest Job No.:	18-11068			
Quotation No.:	Chemtest Sample ID.:	611677			
	Client Sample ID.:	LTHW System			
	Sample Type:	WATER			
	Date Sampled:	23-Apr-2018			
Determinand	Accred.	SOP	Units	LOD	
Iron (Dissolved)	N	1450	µg/l	20	1100

Results - Water

設置 5 週間後



Project: 250 Bishopsgate (LTHW) System

Client: Japan System Planning Co (UK)	Chemtest Job No.:	18-11979			
Quotation No.:	Chemtest Sample ID.:	615887			
	Client Sample ID.:	Natwest Bishopsgate			
	Sample Type:	WATER			
	Date Sampled:	30-Apr-2018			
Determinand	Accred.	SOP	Units	LOD	
Iron (Dissolved)	N	1450	µg/l	20	880

Results - Water

設置 6 及び 7 週間後



The right chemistry to deliver results

Project: 250 Bishopsgate

Results - Water

Client: Japan System Planning Co (UK)	Chemtest Job No.:	18-13396	18-13396
Quotation No.:	Chemtest Sample ID.:	622168	622169
Order No.:	Client Sample Ref.:	Bishopsgate	Bishopsgate
	Client Sample ID.:	LTHW System	LTHW System
	Sample Type:	WATER	WATER
	Date Sampled:	07-May-2018	14-May-2018
Determinand	Accred.	SOP	Units LOD
Iron (Dissolved)	N	1450	µg/l 20 410 510

設置 9 週間後



The right chemistry to deliver results

Project: 250 Bishopsgate LTHW

Results - Water

Client: Japan System Planning Co (UK)	Chemtest Job No.:	18-15076
Quotation No.:	Chemtest Sample ID.:	630291
	Client Sample ID.:	LTHW System
	Sample Type:	WATER
	Date Sampled:	29-May-2018
Determinand	Accred.	SOP Units LOD
Iron (Dissolved)	N	1450 µg/l 20 390

設置 11 週間後



The right chemistry to deliver results

Project: 250 Bishop Gate

Results - Water

Client: Japan System Planning Co (UK)	Chemtest Job No.:	18-16642
Quotation No.:	Chemtest Sample ID.:	636822
Order No.:	Client Sample Ref.:	Bishop Gate
	Client Sample ID.:	250
	Sample Type:	WATER
	Date Sampled:	11-Jun-2018
Determinand	Accred.	SOP Units LOD
Iron (Dissolved)	N	1450 µg/l 20 400